

Reliability Investigation and Evaluation of Off-Grid Solar Photovoltaic (PV) Power System

^{1,*}Awoyinka Tunde Dare., ²Adepoju Taiwo Sholagbade.

¹Department of Physics, Olabisi Onabanjo University, Ago-Iwoye.

²Federal University of Technology, Akure.

Submitted: 31-10-2022

Accepted: 08-11-2022

ABSTRACT:

The reliability of solar photovoltaic power system is the ability of the system to supply to the load, a reasonable continuity and quality of power supply. Reliability of off-grid solar photovoltaic power system has been a cause for concern, especially in Nigeria, where several solar photovoltaic projects has failed and do not last, majorly due to poor understanding of energy consumption [Adeyemo 2013]. This poor understanding of energy consumption propel this work to investigate and evaluate the reliability of an off-grid solar pv powersystem in order to recommend an appropriate percentage of electrical load suitable for any off-grid solar powersystem. Recommending this suitable percentage load for off-grid solar pv systems, will ensure a lasting and reliable off-grid solar power electricity in Nigeria or elsewhere. The load percentage recommended in this work, was determined by investigating and evaluating the reliability of 3.5kVA off-grid solar pv power system under different electrical loads. This 3.5kVA off-grid solar pv power system comprises of 2.4kW solar panel, 9.6kWh Battery capacity, 80A MPPT charge controller and 3.5kVA inverter. The percentage of electrical loads used in investigating the system reliability range from 8.5% to 71% of inverter capacity, 12.5% to 104% of solar panel capacity and 3% to 26% of battery nominal capacity.

The field investigation took a duration of 5 days and several hours. During investigation, solar panel current, load current, and battery voltage were measured and recorded with time, to calculate the back-up time, depth of discharge, power consumption and energy generated, battery voltage depletion rate and current drawn by load. After investigation, the reliability of the system was evaluated and conclusion drawn. The results reveal that the reliability of any off-grid solar pv

powersystem is certain and unfailing if the electrical load is not beyond 25% of solar panel capacity, 6.3% of battery capacity and 17% of inverter capacity.

KEYWORDS: Off-Grid; Battery; Inverter; Solar panel; Electrical Load; Back-up Time; Depth of Discharge; Power Consumption; Energy Generated.

I. INTRODUCTION

Solar energy is a renewable source of energy emitted from the sun, which is harnessed using photovoltaic cells to provide a continuous source of electrical power. The harnessing of solar energy has been globally adopted, such that global solar energy market is projected to reach \$223.3 billion by 2026 (Shruti 2019).

Shruti (2019), described that the global solar energy market which was valued at \$52.5 billion in 2018, is projected to reach \$223.3 billion by 2026, growing at a CAGR (compound annual growth rate) of 20.5% from 2019 to 2026. This is due to increase in environmental pollution and provision of government incentives and tax rebates to install solar panel. In addition, decrease in water footprint associated with solar energy systems has fueled their demand in power generating sectors and that the demand for solar cells has gained major traction owing to rooftop installations.

This astonishing growth has made the adoption of solar electricity, as an alternative means of power generation widely, especially in Nigeria where epileptic power supply is constantly met (Aremu J.O 2019). The power problem in Nigeria gave a rise in demand for solar power electricity and this has led to so many quick and improperly planned solar projects which later resulted to failed and abandoned projects.

According to Adeyemo (2013), who studied the challenges facing solar energy projects in Nigeria, pointed out that poor understanding of energy consumption rate and the lack of planning for expected consumption rate can lead to usage of wrong materials or even batteries of lesser capacity in solar project. He buttressed that the capacity and performance of batteries is a major challenge in solar powered projects, and if batteries can be well managed it would minimise the failure in solar powered projects. Also Mohamed Khalil (2019) pinpoint that, inverter is the most fragile components in the solar pv system and a potential source of failure due to the unexpected failures that can occur in its internal component when overloaded. This explains that no matter how vast a solar power system is, if the battery and inverter is not well managed, the pv system would fail and become unreliable.

To ensure the overall reliability of any solar pv electrical system, good managing of battery and inverter is very essential, and this can be achieved by placing and appropriate percentage of load on the battery and inverter, as the two are the major potential source of failures in a solar pv system.

Ankit Bansal(2016)explains that reliability of solar power system covers all aspects of supplying reliable power to consumers, including adequate facilities required to generate sufficient energy and to distribute energy to consumers. He defines the reliability of solar photovoltaic power system as the ability of the system to supply to the load, a reasonable continuity and quality of power supply.

Hence this work then proceeds to provide the required percentage load for an off-grid solar power system, so as to increase the life span of battery and inverter, and to enhance a continuous and quality power supply. This is achieved by using 3.5kva off-grid solar photovoltaic power system as a sample for reliability investigation and evaluation in this work. The reliability investigation and evaluation of the 3.5kva off-grid solar photovoltaic power system was carried out on the field by connecting four different electrical loads to an installed off-grid 3.5Kva solar power system. The loads are equivalent to different percentage of solar panel capacity, battery capacity and inverter capacity, and the results were determined from the following: the back-up time, depth of discharge, power consumption and energy generated, battery voltage depletion rate and current drawn by load

This 3.5Kva off-grid solar photovoltaic power system used as a sample, is an electrical power system installed 3 months earlier before the investigation, to generate 3.5kW solar electricity, and to power a maximum electrical load of 3Kw by means of photovoltaics only. The major components include 2.4kW solar panels to absorb and convert sunlight into direct current electricity, 9.6kWh battery capacity to store the dc energy generated, and 3.5kVA inverter to convert the dc electricity from solar panels and batteries to alternating current, for AC load consumption.

II. MATERIALS AND METHOD

i. MATERIALS

Battery

Used to store the energy generated from the solar panel and to provide energy source during sunset. Four (4) batteries were used, and each battery is rated 12V 200Ah, connected in series to give 24V and also in parallel to give 400Ah. Therefore, the nominal battery capacity in Ampere hour is 400Ah, and in Kilowatt-hour is 9.6kWh. i.e. $24V \times 400Ah = 9600Wh$ or 9.6kWh

Solar Panel

Eight (8) pieces of solar panel rated 300W each was used to convert sunlight into direct current electricity. The solar panel was connected in series and parallel to supply a higher voltage above the battery voltage, and to yield a total solar energy capacity of 2.4kW. The solar panel brand name is Africell, whose voltage at maximum power (V_{mp}) is 31.7V and current at maximum power (I_{mp}) is 9.46A

Solar Charge Controller

A 60A Maximum Power Point Tracking (MPPT) solar charge controller was used so that it can provide boost charging in cold temperatures and when the battery is low. It charges the battery with current higher than the current drawn from the solar panel, by reducing the high voltage coming from the solar panel to the voltage required to charge the battery, in the process the current is increased in the same ratio the voltage is dropped. The charge controller was also used to monitor the battery voltage via its screen display

Inverter

3.5Kva, 24V pure sine wave inverter was used to power the electrical loads used for evaluation. This inverter can power an electrical load up to 3kw

Electrical Load

200W and 100W incandescent light bulbs was used as load measurement. The load capacity is 2500W, 1200W, 600W and 300W, as described below.

- 2500W load is equivalent to 71% of inverter capacity, 104% of solar panel capacity, and 26% of battery nominal capacity. It consists of 12 pieces of 200W bulbs and a 100W bulb
- 1200W load is equivalent to 34% of inverter capacity, 50% of solar panel capacity, and 12.5% of battery capacity. It was made up of 6 pieces of 200W bulbs.
- 600W load is equivalent to 17% of inverter capacity, 25% of solar panel capacity, and 6.3% of battery capacity. 3 piece of 200W bulbs
- 300W load is equivalent to 8.5% of inverter capacity, 12.5% of solar panel capacity, and 3% of battery capacity. A 200W and 100W bulbs

Digital Multimeter / Clamp meter

RMS digital multimeters and clamp meters were used to measure the voltage and current generated by solar panel and consumed by the loads during investigation.

ii. METHOD

The methodology employ is presented in fig.1. The investigation took a duration of five (5) different days. On each day the investigation begins from 12pm in the day when the sun was at its peak and when the batteries has been fully charged. Then data were measured and recoded every hour from 12pm till the time the inverter signals a low battery voltage. Two digital clamp multimeter was used to measure solar panel current and load current each hour, multimeter was used in measuring the battery voltage. The investigation was carried out on March 9, March 11, March 16, and March 19 – 20 in the year 2021, in Ago-Iwoye Ogun state, Nigeria.





Fig. 1



Procedures:

The steps of the method are explained below:

- **System Inspection**
 The batteries terminal, wires and other terminals connections were inspected and retightened to ensure a tight connection. The strength of the battery was also checked, using battery analyser to ensure that the battery is still strong and suitable for this work. The system was installed in December 2020. Fig.2 is a description of how the solar power system was installed and connected to the load
- **Data Measurement:**

On each day, as described in fig.1, field investigation was carried out and the data were measure and recorded. Day 1, March 9, 2021, 2500W load was connected to the solar power system, and measurement of data were taken per hour till the inverter signals a low battery voltage. On Day 2, March 11, 2021, 1200W load was connected to the system and measurement of data were taken per hour till the inverter signals a low battery voltage. On Day 3 and Day 4, 600W and 300W load was connected to the system respectively, and same measurement procedures were followed.

Table 1 – 4 presents the measured data from Day 1 to Day 4

Table 1, Day 1: March 9, 2021

Time	Load	Current Generated by Solar Panel (Charging Current)	Current Consumed by Load (Inverter)	Battery Voltage
12Pm—1pm	2500W	54.1A	113.1A	26.0V
1pm—2pm	2500W	63.3A	119.5A	24.6V
2pm—3pm	2500W	55.8A	128.9A	22.8
3pm—3.30pm	2500W	32.6A	136.7A	21.5

Table 2, Day 2: March 11,2021

Time	Load	Current Generated by Solar Panel (Charging Current)	Current Consumed by Load (Inverter)	Battery Voltage
12Pm—1pm	1200W	52.8A	51.5A	27.4V
1pm—2pm	1200W	60.2A	51.3A	27.5V
2pm—3pm	1200W	57.5A	51.3A	27.5V
3pm—4pm	1200W	35.6A	52.2A	27.0V
4pm—5pm	1200W	20.3A	54.3A	26.0V
5pm—6pm	1200W	7.8A	57.1A	24.7V
6pm—7pm	1200W	2.4A	60.8A	23.2V
7pm—8pm	1200W	0	65.3A	21.6

Table 3, Day 3: March 16,2021

Time	Load	Current Generated by Solar Panel (Charging Current)	Current Consumed by Load (Inverter)	Battery Voltage
12Pm—1pm	600W	53.4A	25.3A	27.9V
1pm—2pm	600W	62.8A	25.2A	28.1V
2pm—3pm	600W	56.2A	25.2A	28.0V
3pm—4pm	600W	36.6	25.2A	28.0V
4pm—5pm	600W	19.3	25.3A	27.9V
5pm—6pm	600W	9.6	25.7A	27.4V
6pm—7pm	600W	2.6	26.4A	26.7V
7pm—8pm	600W	0	27.2A	25.9V
8pm—9pm	600W	0	28.1A	25.1V
9pm—10pm	600W	0	29.0A	24.3V
10pm—11pm	600W	0	30.0A	23.5V
11pm—12am	600W	0	31.1A	22.7V
12am—1am	600W	0	32.2A	21.9V
1am—1.30am	600W	0	32.8A	21.5V

Table 4: Day 4: March 19 – 20, 2021

Time	Load	Current Generated by Solar Panel (Charging Current)	Current Consumed by Load (Inverter)	Battery Voltage
12Pm—1pm	300W	56.2A	12.7A	27.8V
1pm—2pm	300W	58.7A	12.6A	28.1V
2pm—3pm	300W	53.4A	12.6A	28.1V
3pm—4pm	300W	30.8A	12.6A	28.0V
4pm—5pm	300W	14.2A	12.6A	28.0V
5pm—6pm	300W	6.4A	12.7A	27.8V
6pm—7pm	300W	2.6A	12.8A	27.5V
7pm—8pm	300W	0A	13.0A	27.1V
8pm—9pm	300W	0A	13.2A	26.7V
9pm—10pm	300W	0A	13.4A	26.3V
10pm—11pm	300W	0A	13.6A	25.9V
11pm—12am	300W	0A	13.8A	25.5V
12am—1am	300W	0A	14.0A	25.1V
1am—2am	300W	0A	14.2A	24.7V
2am—3am	300W	0A	14.5A	24.3V
3am—4am	300W	0A	14.7A	23.9V
4am—5am	300W	0A	15.0A	23.5V
5am—6am	300W	0A	15.2A	23.1V
6am—7am	300W	0A	15.5A	22.7V
7am—8am	300W	6.7A	15.6A	22.5V
8am—9am	300W	19.2A	15.6A	22.5V
9am—10am	300W	36.6A	15.5A	22.7V
10am—11am	300W	41.6A	15.3A	23.0V
11am—12pm	300W	56.5A	15.0A	23.5V
12pm—1pm	300W	60.1A	14.6A	24.1V
1pm—2pm	300W	62.7A	14.2A	24.7V

• **Conversion of Data**

After the field investigation of the system was completed, the measured data were converted to calculate the parameters needed in determining the results. The parameters are: depth of discharge, power consumed by load and energy generated from solar panel and battery, battery voltage depletion rate and current consumed by load.

Depth of Discharge

Depth of discharge indicate the percentage of the battery that has been discharged relative to

the capacity of the battery. Depth of Discharge is defined as the capacity that is discharged from a fully charged battery, divided by the nominal capacity

$$DoD = (E_L \div E_B) \times 100$$

E_L = Capacity of Energy discharge by load from battery measured in kWh or Ah

E_B = Nominal battery capacity or Capacity of Energy stored in battery measured in kWh or Ah.

The Nominal battery capacity in this work is 400Ah or 9.6kWh. Depth of discharge is usually

expressed in percentage points, 100% means empty and 0% means full.

Power Consumed by each Load

The power consumed by each load is expressed in kilowatt-hours kWh is calculated using the formula:

$$\text{Power Consumed} = (P \times t) \div 1000$$

Where, P = power units in watts and t = time over which power or energy was consumed

Table 5 – 8 presents the Depth of Discharge and Power Consumed per load using the measured parameters, from day 1 to 5

Table 5: Day 1

Time	Power Consumed	Battery Capacity (E _B)	Discharge Capacity by Load (E _L)	Depth of Discharge
12Pm—1pm	2.5kWh	400Ah	59Ah	14.8%
1pm—2pm	2.5kWh	341Ah	56.2Ah	16.5%
2pm—3pm	2.5kWh	285Ah	73.1Ah	25.7%
3pm—3.30pm	2.5kWh	212Ah	52.1Ah	24.6%

Table 6: Day 2

Time	Power Consumed	Battery Capacity (E _B)	Discharge Capacity by Load (E _L)	Depth of Discharge
12Pm—1pm	1.2kWh	400Ah	0	0%
1pm—2pm	1.2kWh	400Ah	0	0%
2pm—3pm	1.2kWh	400Ah	0	0%
3pm—4pm	1.2kWh	400Ah	16.6Ah	4.2%
4pm—5pm	1.2kWh	383Ah	34Ah	8.9%
5pm—6pm	1.2kWh	349Ah	49.3Ah	14.1%
6pm—7pm	1.2kWh	300Ah	60.8Ah	20.3%
7pm—8pm	1.2kWh	239Ah	65.3Ah	27.3%

Table 7: Day 3

Time	Power Consumed	Battery Capacity (E _B)	Discharge Capacity by Load (E _L)	Depth of Discharge
12Pm—1pm	0.6kWh	400Ah	0	0%
1pm—2pm	0.6kWh	400Ah	0	0%
2pm—3pm	0.6kWh	400Ah	0	0%
3pm—4pm	0.6kWh	400Ah	0	0%
4pm—5pm	0.6kWh	400Ah	6Ah	1.5%
5pm—6pm	0.6kWh	394Ah	16.1Ah	4.1%
6pm—7pm	0.6kWh	378Ah	26.4Ah	7%
7pm—8pm	0.6kWh	352Ah	27.2AH	7.7%
8pm—9pm	0.6kWh	325Ah	28.1Ah	8.6%
9pm—10pm	0.6kWh	297Ah	29.0Ah	9.7%
10pm—11pm	0.6kWh	268Ah	30.0Ah	11.2%
11pm—12am	0.6kWh	238Ah	31.1Ah	13.1%
12am—1am	0.6kWh	207Ah	32.2Ah	15.6%

Table 8: Day 4 – 5

Time	Power Consumed	Battery Capacity (E_B)	Discharge Capacity by Load (E_L)	Depth of Discharge
12Pm—1pm	0.3kWh	400Ah	0	0
1pm—2pm	0.3kWh	400Ah	0	0
2pm—3pm	0.3kWh	400Ah	0	0
3pm—4pm	0.3kWh	400Ah	0	0
4pm—5pm	0.3kWh	400Ah	0	0
5pm—6pm	0.3kWh	400Ah	6.3Ah	1.6%
6pm—7pm	0.3kWh	394Ah	12.8Ah	3.2%
7pm—8pm	0.3kWh	381Ah	13.0Ah	3.4%
8pm—9pm	0.3kWh	368Ah	13.2Ah	3.6%
9pm—10pm	0.3kWh	355Ah	13.4Ah	3.8%
10pm—11pm	0.3kWh	341Ah	13.6Ah	4.0%
11pm—12am	0.3kWh	327Ah	13.8Ah	4.2%
12am—1am	0.3kWh	313Ah	14.0Ah	4.5%
1am—2am	0.3kWh	299Ah	14.2Ah	4.7%
2am—3am	0.3kWh	285Ah	14.5Ah	5.1%
3am—4am	0.3kWh	270Ah	14.7Ah	5.4%
4am—5am	0.3kWh	255Ah	15.0Ah	5.9%
5am—6am	0.3kWh	240Ah	15.2Ah	6.3%
6am—7am	0.3kWh	224Ah	15.5Ah	6.9%
7am—8am	0.3kWh	215Ah	8.9Ah	4.1%
8am—9am	0.3kWh	215Ah	0	0
9am—10am	0.3kWh	236Ah	0	0
10am—11am	0.3kWh	262Ah	0	0
11am—12pm	0.3kWh	303Ah	0	0
12pm—1pm	0.3kWh	348Ah	0	0
1pm—2pm	0.3kWh	395Ah	0	0

Energy Generated from Solar Panel and Battery

The energy supplied by solar panel and the stored energy from the batteries are both referred to as energy generated, and is calculated per hour on each day

$$E_{SB} = E_S + E_B$$

E_{SB} = Energy Generated (Energy generated by solar panel and battery altogether, measured in kWh).

E_S = Energy from Solar panel in kWh = (Solar panel Charging Current \times Solar Panel V_{mp} \times 1 hour) \div 1000

Solar Panel (V_{mp}) = 31.7V

Voltage at maximum power (V_{mp}) was used in calculating E_S , because the MPPT charge controller reduced the high voltage from the solar panel to varying charging voltages, closer or equal to solar panel V_{mp} to charge the battery.

E_B = Energy stored in Battery in kWh = (Battery Ampere \times Battery Voltage \times 1 hour) \div 1000

Table 9 to 12 presents the energy generated per hour from day 1 to 5

Table 9

Time	Power Consumed	Battery Energy (E_B)	Solar Panel Energy (E_S)	Energy generated (E_{SB})
12Pm—1pm	2.5kWh	10.4kWh	1.71kWh	12.1kWh
1pm—2pm	2.5kWh	8.39kWh	2.01kWh	10.4kWh
2pm—3pm	2.5kWh	6.50kWh	1.77kWh	8.3kWh
3pm—3.30pm	2.5kWh	4.56kWh	1.03kWh	5.6kWh

Table 10

Time	Power Consumed	Battery Energy (E_B)	Solar Panel Energy (E_S)	Energy generated (E_{SB})
12Pm—1pm	1.2kWh	10.96kWh	1.63kWh	12.6kWh
1pm—2pm	1.2kWh	11.0kWh	1.91kWh	12.9kWh
2pm—3pm	1.2kWh	11.0kWh	1.81kWh	12.8kWh
3pm—4pm	1.2kWh	10.8kWh	1.13kWh	11.9kWh
4pm—5pm	1.2kWh	9.96kWh	0.64kWh	10.6kWh
5pm—6pm	1.2kWh	8.62kWh	0.25kWh	8.9kWh
6pm—7pm	1.2kWh	6.96kWh	0	6.9kWh
7pm—8pm	1.2kWh	5.16kWh	0	5.2kWh

Table 11

Time	Power Consumed	Battery Energy (E_B)	Solar Panel Energy (E_S)	Energy generated (E_{SB})
12Pm—1pm	0.6kWh	11.16kWh	1.69kWh	12.9kWh
1pm—2pm	0.6kWh	11.2kWh	1.99kWh	13.2kWh
2pm—3pm	0.6kWh	11.2kWh	1.78kWh	13.0kWh
3pm—4pm	0.6kWh	11.2kWh	1.16kWh	12.4kWh
4pm—5pm	0.6kWh	11.16kWh	0.61kWh	11.8kWh
5pm—6pm	0.6kWh	10.8kWh	0.3kWh	11.1kWh
6pm—7pm	0.6kWh	10.09kWh	0	10.1kWh
7pm—8pm	0.6kWh	9.12kWh	0	9.1kWh
8pm—9pm	0.6kWh	8.16kWh	0	8.2kWh
9pm—10pm	0.6kWh	7.22kWh	0	7.2kWh
10pm—11pm	0.6kWh	6.30kWh	0	6.3kWh
11pm—12am	0.6kWh	5.40kWh	0	5.4kWh
12am—1am	0.6kWh	4.53kWh	0	4.5kWh

Table 12

Time	Power Consumed	Battery Energy (E_B)	Solar Panel Energy (E_S)	Energy generated (E_{SB})
12Pm—1pm	0.3kWh	11.1kWh	1.78kWh	12.9kWh
1pm—2pm	0.3kWh	11.2kWh	1.86kWh	13.1kWh
2pm—3pm	0.3kWh	11.2kWh	1.69kWh	12.9kWh
3pm—4pm	0.3kWh	11.2kWh	0.98kWh	12.2kWh
4pm—5pm	0.3kWh	11.2kWh	0.45kWh	11.7kWh
5pm—6pm	0.3kWh	11.1kWh	0.20kWh	11.3kWh
6pm—7pm	0.3kWh	10.84kWh	0	10.8kWh
7pm—8pm	0.3kWh	10.33kWh	0	10.3kWh
8pm—9pm	0.3kWh	9.83kWh	0	9.8kWh
9pm—10pm	0.3kWh	9.34kWh	0	9.3kWh
10pm—11pm	0.3kWh	8.83kWh	0	8.8kWh
11pm—12am	0.3kWh	8.34kWh	0	8.3kWh
12am—1am	0.3kWh	7.86kWh	0	7.9kWh
1am—2am	0.3kWh	7.39kWh	0	7.4kWh
2am—3am	0.3kWh	6.93kWh	0	6.9kWh
3am—4am	0.3kWh	6.45kWh	0	6.5kWh
4am—5am	0.3kWh	5.99kWh	0	6.0kWh
5am—6am	0.3kWh	5.54kWh	0	5.5kWh
6am—7am	0.3kWh	5.08kWh	0	5.1kWh
7am—8am	0.3kWh	4.84kWh	0.21kWh	5.1kWh
8am—9am	0.3kWh	4.85kWh	0.61kWh	5.5kWh
9am—10am	0.3kWh	5.36kWh	1.16kWh	6.5kWh
10am—11am	0.3kWh	6.03kWh	1.32kWh	7.4kWh
11am—12pm	0.3kWh	7.12kWh	1.79kWh	8.9kWh
12pm—1pm	0.3kWh	8.39kWh	1.91kWh	10.3kWh
1pm—2pm	0.3kWh	9.76kWh	1.99kWh	11.8kWh

III. RESULT AND DISCUSSION

The reliability of solar photovoltaic power system was evaluated from the result of the following parameters:

- The Back-up time and Load
- Depth of Discharge and Load
- Power Consumed and Energy Generated
- Battery Voltage Depletion and Current drawn by Load

The result of these parameters are presented in fig.3 – 12 below. The results obtained are from the measured and converted data during investigation, as shown in table 1 – 12 above.

i. Back-up Time versus Load

Back-up time is the total time the battery in the solar pv power system provides power backup on full load until it is fully discharge. The result shows that the higher the load the lesser the time the off-grid solar pv power system provides power backup.

On 2.5Kw load, the backup time was 3 hours and within this three hours, the battery voltage drops very rapidly. The cause of this rapid voltage drop was due to high current consumed by the 2.5kW load, as discussed better in fig.11. A 3 hours backup is an inadequate backup time for any off-grid solar power system, as it does not make it a reliable solar

power system. Similar low backup time occurred for 1.2kW load, the backup time was 8 hours and also not reliable enough for an off-grid solar pv system. On 0.6kW and 0.3kW load, the solar pv power system provide more than 12 hours power

backup for these loads, which is considered a reliable backup time per day, especially the 0.3kW load defines a recommended load percentage to make a continuous backup time and a highly reliable off-grid solar power system.




Fig. 3

ii. **Depth of Discharge and Load**

Fig. 4 to 8 present the rate of depth of discharge with each load. A depth of discharge at 0% means the battery has not been discharged, while at 100% means it has been completely discharge. When the battery is fully charged with excess energy generated by the solar panel, the DoD will be closer to 0%. This makes the DoD on 0.3kw load reduces gradually back to 0% on day 5 after 20 hours of discharge. The DoD on 0.3kw load for 20 hours discharge duration was 66% and the DoD on 0.6kw load was 78.5% with 13 hours discharge duration. This DoD is highly reliable for the batteries lifespan, especially when considering the duration of discharge. The duration of discharge determines how faster a battery is cycled or how soon a battery will complete a cycle. A battery cycle is one complete discharge and recharge cycle. A battery completes a cycle when it discharges 100% and recharge 100%. if a battery is discharged to 50% and then recharged, it has completed a half cycle, while discharging it to 50% again and recharging it again results in one complete cycle — 100%

On 0.3kw load, the batteries were discharged for 20 hours to 66%, and then recharge again from 66% to complete at two-third 2/3 cycle, as a result, the batteries will complete a cycle in 3 days. Similarly, on 0.6kw load, the batteries will complete a cycle in 2 days at 78.5% DoD and 13 hours of discharge. Considering the DoD of 2.5kw and 1.2kw, 2.5kw DoD was 81.6% at 3 hours discharge duration, thereby completing a cycle in 1 day. The same applies to 1.2kw load at 74.8% DoD and a discharge duration of 8 hours. This high rate of discharge on both 2.5kw and 1.2kw load is not good for the cycle and lifespan of the battery. The lifespan of a battery depends on how deep a battery is cycled each time. Therefore, the battery cycle rate on 2.5kw and 1.2kw load was faster than the cycle rate of 0.6kw and 0.3kw load, and this will quickly shorten the battery lifespan, thereby making the off-grid solar power system unreliable.




Fig. 4




Fig. 5




Fig. 6

Fig. 7





Fig. 8

Power Consume and Energy Generated

As shown in Fig 9 – 10, the result shows that power consumed by 2.5Kw and 1.2kW load drained the energy generated by solar panel and battery at a very high rate, compare to 0.6kw and 0.3kw load. On 2.5kw load, a total power of 7.5kWh was consumed within the 3hour backup time and the total energy generated within this backup time was 36.4Kw. For 1.2kw load, the power consumed and the energy generated/supplied was 9.6kWh and 81.8kWh respectively, within the 8hour backup time. 7.8kWh power was consumed by 0.6kW load and a total of 125.2kWh energy was supplied for 13hours duration, while 7.8kWh power was consumed by 0.3kW load and a total energy of 232.2kWh was supplied for 24hours duration and above. This shows in fig.10 that despite the total power consumed by each load are closer, the

energy supplied by battery and solar panel were drained at different rate. This can be explained by the current consumed by each load which are highly different. 2.5Kw and 1.2Kw load drawn a current greater than the current generated from the solar panel and thereby compliment this current differences by drawing additional current from the battery which makes the battery voltage and the combined energy supplied decreases with time. While 0.6kw and 0.3kw uses current far below the current generated by the solar panel, and this makes room for excess current from the solar panel to be stored by the battery, thereby allowing the battery to have ample time to store more energy for supply. This enhances a reliable solar power electricity on 0.3kw and 0.6kw load per day. Using 2.5kw and 1.2kw load, considering its high power and current consumption, will make an off-grid solar power system unreliable fail with time




Fig. 9




Fig. 10

Battery Voltage Depletion and Current drawn by Load

Fig11 – 14 depicts the rate at which battery voltage drops with the current drawn by each load. The graph shows that the higher the current drawn by load through the inverter, the faster the battery voltage drop and the lower the current the lesser the battery voltage drop. On 2.5Kw and 1.2kW load, the battery voltage drops very rapidly to 21v within 3hours. This high depletion of battery voltage on 2.5kw and 1.2kw load occurs due to high current, drawn by the loads, which makes the battery voltage deplete very

rapidly and generally resulted to low backup time, high depth of discharge, and low energy stored/supplied by the battery. This continuous rapid voltage depletion like this will not make an off-grid solar power system continuous and reliable. Dissimilarly, on 0.6kw and 0.3kw load, the battery voltage depletes slowly due to the low current drawn by the load, which allows enough excess energy from the solar panel to be stored by the battery, and this generally enhances high backup time, low depth of discharge, and high energy stored/supplied by the battery and thereby making an off-grid solar pv power system reliable and continuous.




Fig. 11




Fig. 12




Fig. 13




Fig. 14

IV. CONCLUSION

The reliability of off-grid solar photovoltaic system has been investigated and evaluated under different electrical loads percentage, by using 3.5kva off-grid solar power system as a sample. The parameter evaluated during investigation were, the back-up time, depth of discharge, power consumption and energy generated, battery voltage depletion rate and current drawn by load. The result reveals that an off grid solar pv power system will fail and become unreliable when connected to electrical loads that exceed 25% of its solar panel capacity, 6.3% of its battery capacity and 17% of its inverter capacity. These are attributed to four main reasons: low back-up time, high depth of discharge, high power consumption above the energy generated, high battery voltage depletion rate due to high current drawn by such load. The result further depicts that for an off-grid solar pv system to be reliable and continuous, it should have a long backup time ranging from 12 hours backup per day and above, a moderate depth of discharge not exceeding 80% and a minimal energy consumption so that the energy generated from solar panel would be excess to charge the battery effectively, thereby reducing the rate of battery voltage depletion. In achieving this, it is therefore concluded based on the higher backup time, low depth of discharge and low current consumption and voltage depletion achieved in this work using 0.6kw and 0.3kw loads, that the percentage electrical load appropriate for an off grid solar pv system to make it reliable, should range from 12.5% - 25% of solar panel capacity for excess energy generation, 3% - 6.3% of battery capacity for efficient storage of the excess energy and 8.5% - 17% of inverter capacity for ensuring a minimal current consumption and for preventing a rapid battery voltage depletion. Any electrical load above this

percentage range will make an off-grid solar photovoltaic power system unreliable.

REFERENCES

- [1]. Shruti Hariharan. (Oct. 2019). "Solar Energy Market." [On-line] Available: www.alliedmarketresearch.com/solar-energy-market [April 5, 2021].
- [2]. Adeyemo Hakeem, 2013, "Challenges Facing Solar Energy Projects in Nigeria: A Case Study of Lagos State." Bachelor's thesis, HAMK University of Applied Science – May 2013
- [3]. Aremu, J.O. 2019, "Epileptic Electric Power Generation and Supply in Nigeria: Causes, Impact and Solution. Journal of Contemporary Research in Social Science
- [4]. Mohamed Khalil, 2019, "Failure Prediction of PV Inverters under Operational Stresses" DOI:10.1109/EEEIC.2019.8783241 Conference: 2019 IEEE International Conference on Environment and Electrical Engineering and 2019 IEEE Industrial and Commercial Power System Europe – June 2019.
- [5]. Ankit Bansal 2016 "Reliability Evaluation of Solar Photovoltaic Power System: A synopsis submitted in partial fulfillment of the requirement for the degree of doctor of Philosophy" Department of Electrical Engineering, Dayalbagh Educational Institute – Sept 2016