

Design and Fabrication of Hybrid Solar Wind Power Generation System

M. Arun¹, V. Muthu Kumar², S. Ram Rithik³, V.D.S.Ashwin

1, 2, 3, Students III BE DEPARTMENT OF MECHANICAL ENGINEERING, 4 Faculty of Mechanical Engineering, Jayamatha Engineering College Aralvoimozhi.

Submitted: 01-06-2022

Revised: 10-06-2022

Accepted: 15-06-2022

ABSTRACT: Renewable energy sources that is. energy generated from solar, wind, biomass, hydro power, geothermal and ocean resources are considered as a technological option for generating clean energy. But the energy generated from solar and wind is much less than the production by fossil fuels, however, electricity generation by utilizing PV cells and wind turbine increased rapidly in recent years. This paper presents the Solar-Wind hybrid Power system that harnesses the renewable energies in Sun and Wind to generate electricity. System control relies mainly on micro controller. It ensures the optimum utilization of resources and hence improves the efficiency as compared with their individual mode of generation. Also it increases the reliability and reduces the dependence on one single source. This hybrid solar-wind power generating system is suitable for industries and also domestic areas.

I. INTRODUCTION

With increasing concern of global warming and the depletion of fossil fuel reserves, many are looking at sustainable energy solutions to preserve the earth for the future generations. Other than hydro power, wind and photovoltaic energy holds the most potential to meet our energy demands. Alone, wind energy is capable of supplying large amounts of power but its presence is highly unpredictable as it can be here one moment and gone in another. Similarly, solar energy is present throughout the day but the solar irradiation levels vary due to sun intensity and unpredictable shadows cast by clouds, birds, trees, etc. The common inherent drawback of wind and photovoltaic systems are their intermittent natures that make them unreliable. However, by combining these two intermittent sources and by incorporating maximum power point tracking (MPPT) algorithms, the systems power transfer efficiency and reliability can be improved significantly. When a source is unavailable or insufficient in meeting the load demands, the other energy source can compensate for the difference.

II. OBJECTIVE

To reduce reliance on fossil fuels and increase the share of renewable energy resources, including intermittent ones, thus increasing the ecoefficiency of energy production and energy security. To bring together different generation, storage, and consumption technologies in a single system, improving the overall benefits compared to a system that depends on a single source. It is type of hybrid energy system consist of a photovoltaic array coupled with a wind turbine. This would create more output from the wind turbine during the winter, whereas during the summer, the solar panels would produce their peak output. The PVwind hybrid system suits to conditions where sun light and wind has seasonal shifts. In summer the daytime is long and sun light is strong enough, while in winter the days are shorter and there are more clouds. Inverters can also provide a utility inter-tie between the system and the utility grid.

SYSTEM COMPONENTS

- A photo-voltaic solar-cell array
- A mast mounted wind generator
- Lead-acid storage batteries
- An inverter unit to convert DC power to AC power
- Electrical lighting loads and electrical heating loads

CHARGE CONTROLLER REGULATOR

- It prevents the PV array and wind turbine from over- charging the battery.
- Most modern controllers maintain system voltage regulation electronically by varying the width of DC pulses they send to the batteries



(this is called pulse width modulation or PWM).

- Another category called "shunt type" controllers divert excess energy into a "shunt load."
- A new generation of PV controllers has "maximum power point tracking." They take advantage of the maximum power available in the module by adjusting current and voltage.

DESIGN OF HYBRID ENERGY SYSTEM

Data required for Wind System

- Mean Annual Hourly Wind Speed (m/sec)
- Wind Power that can be generated from the wind turbine

This design includes following requirements.

- Solar panel
- Wind turbine
- Charge controller
- Battery bank
- Inverter

3D DESIGN

The design diagram of the hybrid system is done by CREO software the parts are first drawn separately and assemble into single part.



FABRICATION

The capacity of the panel are 20w and 18v, the alternator has 12v capacity and the battery has 12v capacity the frame of the hybrid system in made up of mild steel and the steels are weld jointed .The rest of the components are

S.No.	Description	Quantity
1	Motor	1 No
2	Rotor Gear	1 No

3	Solar Panel	1 No
4	Battery	1 No
5	Bolt & Nuts	10 Nos
6	Wires	15mtrs
7	Blades	10 Nos
8	Chassis Assembly	-
9	Miscellaneous Expenses	-

CALCULATIONS

The total power generated by this system may be given as the addition of the power generated by the solar PV panel and power generated by the wind turbine. Mathematically it can be represented as, $P_T = NW * Pw + Ns * P_S$

 P_{T} is the total power generated

 $P_{\rm W}$ is the power generated by wind turbines

 P_{S} is the power generated by solar panels

 N_w is the no of wind turbine

 N_s is the no of solar panels used

CALCULATIONS FOR WIND ENERGY

The power generated by wind energy is given by, Power = (density of air * swept area * velocity cubed)/2

 $P_{W} = \frac{1}{2} \rho (A_{W}) (V)^{3}$

Where,

P is power in watts (W)

 ρ is the air density in kilograms per cubic meter (kg/m³)

 A_W is the swept area by air in square meters (m²) V is the wind speed in meters per second (m/s).

CALCULATIONS FOR WIND ENERGY

To determine the size of PV modules, the required energy consumption must be estimated. Therefore, the power is calculated as

 $P_S = Ins (t) * A_S * Eff(pv)$

Where.

Ins (t) = isolation at time t (kw/m2)

 A_{S} = area of single PV panel (m2)

Effpv = overall efficiency of the PV panels and dc/dc converters.

Overall efficiency is given by,

Eff(pv) = H * PR

Where,

H = Annual average solar radiation on tilted panels.

PR = Performance ratio, coefficient for losses.



III. RESULT ANALYSIS

According to the optimal solution the total energy required to satisfy the load demand by the hybrid combination. Below figures shows the monthly average electric production from wind energy and solar energy in graph format. Table shows the electric energy production from hybrid power generation using solar and wind.

	Hybrid Power Generation System PV & Wind
Period (sec)	0 to 0.3
Input Solar irradiations	20 W/m2
Input Wind Velocity	8 m/s
Voltage (V)	11.5
Current (A)	1.4
Power (W)	16

APPLICATIONS

- Hotels
- Business (Institutions and Government)
- Large Estate Houses
- Factories and manufacturing facilities
- Commercial Power generation

REFERENCES

- Abhaya Swarup, Mishra P.K. and Swarup P. (1999) 'Energy Management through computer program for modeling PV energy systems', Proceedings of the 23rd National Renewable Energy Convention of the SESI, pp. 151-154.
- [2]. Martina Calais, Vassilios G. Agelidis and Mike Meinhardt (1999) 'Multilevel converters for single-phase grid connected photovoltaic systems: An overview', Solar Energy, Vol. 66, No. 5, pp. 325-335.
- [3]. VivekKapil, Fernandez E. and Saini R.P.(1999)'Design of Photovoltaic system for remote areas', Proceedings of the 23rd National Renewable Energy Convention of the SESI, pp. 145-147.
- [4]. Bhattacharaya N.K. and Mukherjee D. (2001) 'A simplified Design approach and economic appraisal of a solar photovoltaic powered rural health center in West Bengal', Proceedings of the 25th National Renewable Energy Convention of the SESI, pp. 158-164.

- [5]. Kaushika Anil K. Rai, Kshitij Kaushik and Mishra A. (2001) 'Knowledge based approach to the design of solar PV systems', Proceedings of the 25th National Renewable Energy Convention of the SESI, pp. 165-170.
- [6]. Hamid Marafia A. (2001) 'Feasibility study of photovoltaic technology in Qatar', Renewable Energy, Vol. 24, pp. 565-567.
- [7]. Mohanlal Kolhe, Sunita Kolhe and Joshi J.C. (2002) 'Economic viability of standalone solar photovoltaic system in comparison with dieselpowered system for India', Energy Economics, Vol.24, pp.155-165.
- [8]. Usha Bajpai and Suresh C Bajpai (2003) 'Some aspects of array and storage battery sizing in standalone photovoltaic power systems', Proceedings of the 26th National Renewable Energy Convention of the SESI, pp. 222-227.
- [9]. Aydogan Ozdamar, HasanYildiz and OzgurSar (2001) 'Wind energy utilization in a house in Izmir, Turkey', International Journal of Energy Research, Vol. 25, pp. 253-261.
- [10]. Kanat A. Baigarin and Andre de Boer 'Potential of renewable energy resources in Central Asia', A text book on Renewable Energy, pp.73- 80.
- [11]. Suresh H., Jangam shetti, and Guruprasada Rau V. (2001) 'Optimum siting of wind turbine generators', IEEE Transactions on Energy Conservation, Vol. 16, pp. 8-13.
- [12]. Wen-jei Yang and Orhan Aydin (2001) 'Wind energy-hydrogen storage hybrid power', Generation International Journal of Energy Research, Vol. 25, pp. 449-463.
- [13]. Bhave A.G. (1999) 'Hybrid solar-wind domestic power generating system-a case study', Renewable Energy, Vol. 17, pp. 355-358.
- [14]. Habib M.A., Said S.A.M., El-Hadidy M.A. and Al-Zaharna I. (1999) 'Optimization procedure of hybrid photovoltaic wind energy system', Energy, Vol. 24, pp. 919-929.
- [15]. Francois Giraud and Zyiad M. Salameh (2001) 'Steady-state performance of a Gridconnected roof top hybrid wind-photovoltaic power system with battery storage', IEEE Transactions of Energy Conversion, Vol. 16, pp. 1-6.
- [16]. Rajesh Karki and Roy Billinton (2001) Reliability/cost implications of PV and wind energy utilization in small isolated power

DOI: 10.35629/5252-040610381041 Impact Factor value 7.429 | ISO 9001: 2008 Certified Journal Page 1040



systems', IEEE Transactions on Energy Conversion, Vol. 16, No. 4, pp. 368-373.

- [17]. Celik A.N. (2002) 'Optimisation and technoeconomic analysis of autonomous photovoltaic – wind hybrid energy systems in comparison to single photovoltaic and wind systems', Energy Conversion and Management, Vol. 43, pp. 2453-2468.
- [18]. Yang H.X., Burnett L. and Lu J. (2003) 'Weather data and probability analysis of hybrid photovoltaic-wind power generation systems in Hong Kong', Renewable Energy, Vol. 28, p. 1813-1824.
- [19]. Celik A.N. (2003) 'Techno-economic analysis of autonomous PV-wind hybrid energy systems using different sizing methods', Energy Conversion and Management, Vol. 44, pp. 1951- 1968.
- [20]. Bitterlin I.F. (2005) 'Modelling a reliable wind/PV/storage power system for remote radio base station sites without utility power', Power Sources.
- [21]. Tina G, Gagliano S. and Raiti S (2005) `Hybrid solar/wind power system probabilistic modelling for long-term performance assessme Solar Energy.
- [22]. Dr. Recayi Recan et.al 'A Hybrid Solar Wind Power Generation System As An Instructial Resources For Industrial Technology Student'- Journal of Industrial Technology – Volume 16, number 3 May 2000 to July 2000
- [23]. K. Shivarama Krishna et.al 'Dynamic Modeling and Control of Grid Connected Hybrid Wind/PV Generation System'-International Journal of Engineering Research and Development - Volume 10 issue 5 May 2014
- [24]. P. Sandeep et.al 'Modeling And Operations Of Micro grid With Wind Photovoltaic Resources'-Industrial Research Journal of Engineering Technology – Volume 2 issue 4 July 2015
- [25]. Nejmeddine BahriK et.al 'Intelligent Power Supply Management Of An Autonomous Hybrid Energy Generator '-Industrial Journal of Substantial Engineering – Volume 12 issue 5 March 2019